

## **1. INTRODUCTION**

The subsoil investigations reported herein were taken up to find out the nature of subsoil at the site of the proposed construction and to recommend the capacity and type of its foundation. After certain tests on the soil, as detailed below, the desired recommendations have been made on **page 3 - 4** of this Report.

## **2. FIELD WORK**

The fieldwork consisted of sinking bore holes, collecting soil samples and conducting the necessary field tests.

### **2.1. Boring**

Taking guidance from IS: 1892, 150 mm diameter bore holes were sunk at locations shown in the bore hole location map.

### **2.2 Sampling**

#### **2.2.1 Undisturbed Soil Samples**

Open drive samplers of 100-mm diameter and about 450-mm length were used for obtaining undisturbed samples of cohesive soils. The collection, sealing, labeling and transportation of the samples to the laboratory were done as per the IS guide-lines.

#### **2.2.2 Disturbed Soil Samples**

Disturbed soil samples were collected at suitable intervals of depth (not more than 2.5 m) and at all depths of change in the nature of the subsoil. These samples were sealed in polythene bags with proper identification labels.

### **2.3 Field Tests**

#### **2.3.1 Standard Penetration Tests (SPT)**

These tests were conducted as per IS: 2131 – 1963. The depth interval between two consecutive tests was 1 to 1.5 m. The tests were located in between the levels at which undisturbed soil samples were collected.

Report on Sub Soil Investigations for the Proposed  
**Educational Building at Head Quarter Dist. Bhojpur**

**3. LABORATORY TESTS**

Some or all of the following laboratory tests, as necessary, were done on the collected soil samples. Representative soil samples were selected for this from the different soil strata encountered during boring. The tests were performed as per the relevant Indian Standard Codes of Practice.

- (a) Natural moisture content
- (b) Bulk density
- (c) Grain size analysis (using sieves and / or hydrometer)
- (d) Specific gravity of soil solids
- (e) Atterberg's limit tests (liquid, plastic and shrinkage limits)
- (f) Shear Tests :
  - [I] Triaxial compression test (unconsolidated – undrained), generally for fine- grained soils
  - [II] Unconfined compression tests, only on cohesive soils
  - [III] Direct shear tests, generally for coarse-grained soils
- (g) Other tests as and when required.

**4. PRESENTATION OF TEST RESULTS**

The field and laboratory test are given in the **Appendix B**.

**5. SOIL STRATIFICATION**

The results of field tests in three bore hole sunk at the site [vide Location Sketch in App. A] and the results of laboratory tests conducted on the collected soil samples indicate that the soil stratification at the site is as describe below.

The sub soil in all BH's is sandy silty clay / silty clay [type CL / CI] up to the investigated depth of 10.5 m bgl.

*Ground water table was struck at about 3.00 m to 3.10 m depth below GL in November, 2019. It is subject to seasonal variations.*

**6. FOUNDATION ANALYSIS**

The safe capacity of foundation of any type and size may be determined on the basis of the soil data given in this Report by using the standard methods of foundation design and following the relevant Indian Standard Codes.

Report on Sub Soil Investigations for the Proposed  
**Educational Building at Head Quarter Dist. Bhojpur**

**7. RECOMMENDATIONS**

The design of the foundation for the proposed G+4 building structure depends on the nature of both [a] the subsoil and [b] the structure.

The sub soil in all BH's is sandy silty clay / silty clay [type CL / CI] up to the investigated depth of 10.5 m bgl.

*Ground water table was struck at about 3.00 m to 3.10 m depth below GL in November, 2019. It is subject to seasonal variations.*

Hence,

1. The proposed structure may be provided with shallow foundation at a depth of 2.0 m or more. As the formation up to 2 m is very soft.
2. As the shallow foundation may not give a suitable foundation alternatively U/R pile of depth 4.0 m to 8.0 m may be used. Their stem diameters may be taken as 0.25 m, 0.30 m and 0.40 m and the bulb diameters may be taken 0.50 m, 0.60 m and 0.80 m respectively.

By way of example, the values of safe capacities of

(1) Shallow foundations

(2) Single or double bulbed u/r piles of the above mentioned sizes and depths have been calculated (vide Samples of Calculations in Appendix F) and are tabulated below.

**The value of Modulus of subgrade reaction is given at the bottom of Table 2.**

**Table 1: Allowable Net Bearing Pressures [  $q_{na}$  ] and Settlements Expected [s]**

Depth (m)	Width (m)	Net allowable bearing pressure (t/m <sup>2</sup> ) for			Maximum expected settlement (mm)
		Strip footing	Square footing	Raft footing	
2.0	2.0	5.4	6.4	...	75
	3.0	5.0	6.1	...	75
	10.0	...	...	5.7	100
2.5	2.0	6.0	7.2	...	75
	3.0	5.6	6.7	...	75
	10.0	...	...	6.2	100
3.0	2.0	6.9	8.2	...	75
	3.0	6.4	7.6	...	75
	10.0	...	...	6.9	100
3.5	2.0	8.2	9.8	...	75
	3.0	7.2	9.0	...	75
	10.0	...	...	8.0	100
4.0	2.0	9.6	11.5	...	75
	3.0	8.0	10.4	...	75
	10.0	...	...	8.6	100

Report on Sub Soil Investigations for the Proposed  
**Educational Building at Head Quarter Dist. Bhojpur**

**Table 2. Safe Capacities of U/R Piles [Factor of safety = 2.5]  
[Bulb diameter = 2.0 times the shaft diameter]**

Pile length below pile Cap (m)	Stem diameter (m)	Bulb diameter (m)	[b] Safe Pile Capacity (subject to checking for slenderness ratio) [tonnes]	
			One bulb	Two bulbs
4.0	0.25	0.50	3.3	4.1
	0.30	0.60	4.5	5.6
	0.40	0.80	7.4	9.4
6.0	0.25	0.50	5.2	6.2
	0.30	0.60	7.0	8.4
	0.40	0.80	11.3	13.9
8.0	0.25	0.50	7.0	8.6
	0.30	0.60	9.3	11.5
	0.40	0.80	14.6	18.6

**Modulus of subgrade reaction (k):**

For preliminary estimates in clay soils, the following empirical relation as given in IS: 2950-1981 (Second Revision) Table 1, may be used based on the value of cohesion  $c$  of the soil at the concerned depth:

$$k \text{ (kN/m}^3\text{)} = 240 c, \text{ c being in kN/m}^2.$$

**Notes :**

1. If a subsoil condition much different from those reported herein is met with during foundation trenching or piling, suitable steps should be taken.
2. If concreting of piles is to be done below water table, DMC and tremie method should be adopted.
3. If u/r piles are provided, care should be taken to ensure proper formation of bulbs.
4. Shallow foundations or pile caps should be isolated from the surrounding expansive soil by layers of compacted local sand.
5. As per the provisions of the IS Code, **an appropriate number of piles must be subjected to routine load tests to check the veracity of the above recommended values of the safe capacities of piles.**

For Bihar Foundation Consultants

(Dr. K.S.P. Singh, FIE, MIGS)  
Senior Consultant.