

BIHAR STATE EDUCATIONAL INFRASTRUCTURE DEVELOPMENT CORPORATION LTD.

(A Govt. Of Bihar Undertaking)

Shiksha Bhawan, Bihar Rastrabhasa Parishad Campus, Acharya Shiv Pujan Sahay Path, Saidpur,
PATNA-800004. (Tel. No: 0612-2910314)


Letter no.:- BSEIDC/TECH/143/2013 - 2575

Date:- 27.05.14

CORRIGENDUM - 2

1. The width of door (Type D) as mentioned in "Schedule of doors and Windows" shall be read as 1200 mm instead 1500 mm.
2. A window of size 3'0" (Width) X 4'0" (Height) to be provided in each "Principle office" and "Girls common room" at G. Floor and in "Ladies staff room" and "Gents staff room" at First Floor (as per revised drawing attached).
3. 10" thick Brick Work with 4" RCC band up to sill level (+3'0") with grill up to lintel level (+8'0") to be provided in front Passage along grid no. (9) from (D) to (H) and from (J) to (N) as per revised drawing attached.
4. All grill work of 8 mm square bar to be replaced by 10 mm square bar.
5. Bifold grills to be provide in front entrance of Portico from Grid (H) to (J).


Chief Engineer
BSEIDC, Patna.


Arch. 27.5.13

